

Parsippany-Troy Hills Board of Education

**Press Release
Office of the Superintendent
May 9, 2016**

Final Water Testing Results Eastlake Elementary School

We notified you earlier that as a result of the issue of lead in the schools drinking water in Newark, New Jersey, the Parsippany-Troy Hills Township School District made the decision to have the water tested in all of our 14 schools. As part of the testing procedures, all drinking fountains, food preparation, and Home Economics classrooms were tested. We released the partial results for Eastlake Elementary School and now have the final results that will be posted on our website.

Eastlake Elementary School:

All other samples in the school were below the threshold of 15 ppb.

This concludes the water testing for Eastlake Elementary School.

Below is the link to the updated NJDEP website on lead in drinking water
<http://www.nj.gov/dep/watersupply/dwc-lead.html>

The Township website has the most recent State mandated water quality testing program. This is the link to the most recent water quality testing report.

http://www.parsippany.net/web_content/acrobat/flyers/2012-WaterCCR.pdf

For more information regarding lead in drinking water please visit: <https://www.epa.gov/your-drinking-water/basic-information-about-lead-drinking-water>

If you have questions or concerns, please contact Mr. David Corso, Assistant Superintendent of Schools/Chief Financial Officer at dfcorso@pthsd.net.



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

cinnaminsonleadlab@emsl.com

EMSL Order:	201604253
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 04/21/16 9:00 AM
 Collected: 4/20/2016

Project: Parsippany BOE / #0710247 / East Lake Elementary School 40 EBA Road Parsippany, NJ

Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
1	201604253-0001	4/20/2016	5/4/2016	12.9 ppb
Site: EES / Slop Sink on Back of Boiler Rm / UF / 1				
2	201604253-0002	4/20/2016	5/4/2016	3.25 ppb
Site: EES / Nurses Office / Sink / UF / 1				
3	201604253-0003	4/20/2016	5/3/2016	6.08 ppb
Site: EES / Classroom #22 / 4th Grade / WC / 1				
4	201604253-0004	4/20/2016	5/4/2016	7.68 ppb
Site: EES / Classroom #20 / 5th Grade / WC / 1				

Phillip Worby, Lead Laboratory Manager
or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 05/05/2016 18:09:56