

# **Parsippany-Troy Hills Board of Education**

---

**Press Release  
Office of the Superintendent  
April 28, 2016**

## **Water Testing Lake Parsippany and Littleton**

We notified you earlier that as a result of the issue of lead in the schools drinking water in Newark, New Jersey, the Parsippany-Troy Hills Township School District made the decision to have the water tested in all of our 14 schools. As part of the testing procedures, all drinking fountains, food preparation, and Home Economics classrooms were tested. We told you that as results came in we would notify you and post all results on our district website.

Today we received partial results for Lake Parsippany and Littleton Elementary Schools. **All partial results were found to be under the threshold.** There was an error on the part of the consultant and not all the rooms were tested. The remaining classrooms will be tested. Once the complete results are received we will send them out and post them on the district website as we have done for our other schools.

### **Lake Parsippany Elementary School Partial Results:**

The Lake Parsippany Elementary School showed results all below the threshold of 15.0 ppb.

### **Littleton Elementary School Partial Results:**

The Littleton Elementary School showed results all below the threshold of 15.0 ppb.

Please understand that the information we have received is preliminary and not the complete report. The steps taken at this point are precautionary. As we receive additional notifications for the remaining schools and complete testing results for all our schools we will post the information on the District website. [www.pthsd.k12.nj.us](http://www.pthsd.k12.nj.us)

Below is the link to the updated NJDEP website on lead in drinking water  
<http://www.nj.gov/dep/watersupply/dwc-lead.html>

The Township website has the most recent State mandated water quality testing program. This is the link to the most recent water quality testing report.  
[http://www.parsippany.net/web\\_content/acrobat/flyers/2012-WaterCCR.pdf](http://www.parsippany.net/web_content/acrobat/flyers/2012-WaterCCR.pdf)

For more information regarding lead in drinking water please visit: <https://www.epa.gov/your-drinking-water/basic-information-about-lead-drinking-water>

If you have questions or concerns, please contact Mr. David Corso, Assistant Superintendent of Schools/Chief Financial Officer at [dfcorso@pthsd.net](mailto:dfcorso@pthsd.net).



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

[cinnaminsonleadlab@emsl.com](mailto:cinnaminsonleadlab@emsl.com)

EMSL Order:	201603705
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**  
**Whitman Companies, Inc.**  
**7 Pleasant Hill Rd**  
**Cranbury, NJ 08512**

Phone: (732) 390-5858  
 Fax: (732) 390-9496  
 Received: 04/07/16 9:00 AM  
 Collected: 4/6/2016

Project: **Parsippany BOE #0710247 / Littleton Elementary School 51 Brooklawn Drive Morris Plains, NJ**

## Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
1	201603705-0001	4/6/2016	4/27/2016	9.80 ppb
Site: LES / By Boiler Rm Custodial Closet / Slop Sink / UF / 1				
2	201603705-0002	4/6/2016	4/27/2016	3.45 ppb
Site: LES / Hall 1 by Classroom #7 / WC / 1				
3	201603705-0003	4/6/2016	4/27/2016	3.68 ppb
Site: LES / Hall 2 by Classroom #9 / WC / 1				
4	201603705-0004	4/6/2016	4/27/2016	3.64 ppb
Site: LES / Hall 3 Between Boys & Girl's Room / WC / Left / 1				
5	201603705-0005	4/6/2016	4/27/2016	4.56 ppb
Site: LES / Hall 3 Between Boys & Girl's Room / WC / Right / 1				
6	201603705-0006	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Classroom #15 / WC / 1				
7	201603705-0007	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Hall 1 by Main Office / WC / Left / 1				
8	201603705-0008	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Hall 1 by Main Office / WC / Right / 1				
9	201603705-0009	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Classroom #5 / Kindergarden / WC / 1				
10	201603705-0010	4/6/2016	4/27/2016	3.07 ppb
Site: LES / Classroom #4 / Kindergarden / WC / 1				
11	201603705-0011	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Classroom #3 / Kindergarden / WC / 1				
12	201603705-0012	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Classroom #2 / Kindergarden / WC / 1				
13	201603705-0013	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Hall 2 Across Media Center & Comp Lab / WC / 1				
14	201603705-0014	4/6/2016	4/27/2016	6.49 ppb
Site: LES / Classroom #25 / WC / 1				
15	201603705-0015	4/6/2016	4/27/2016	12.1 ppb
Site: LES / Classroom #26 / WC / 1				

Phillip Worby, Lead Laboratory Manager  
or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 04/28/2016 11:31:33



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

[cinnaminsonleadlab@emsl.com](mailto:cinnaminsonleadlab@emsl.com)

EMSL Order:	201603705
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**  
**Whitman Companies, Inc.**  
**7 Pleasant Hill Rd**  
**Cranbury, NJ 08512**

Phone: (732) 390-5858  
 Fax: (732) 390-9496  
 Received: 04/07/16 9:00 AM  
 Collected: 4/6/2016

Project: Parsippany BOE #0710247 / Littleton Elementary School 51 Brooklawn Drive Morris Plains, NJ

## Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
16	201603705-0016	4/6/2016	4/27/2016	10.6 ppb
Site: LES / Classroom #24 / WC / 1				
17	201603705-0017	4/6/2016	4/27/2016	<3.00 ppb
Site: LES / Hall by Classroom #19 / WC / 1				
18	201603705-0018	4/6/2016	4/27/2016	4.20 ppb
Site: LES / Classroom #10 / WC / 1				
19	201603705-0019	4/6/2016	4/27/2016	3.64 ppb
Site: LES / Classroom #11 / WC / 1				
20	201603705-0020	4/6/2016	4/27/2016	3.23 ppb
Site: LES / Classroom #13 / WC / 1				

Phillip Worby, Lead Laboratory Manager  
or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 04/28/2016 11:31:33



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

[cinnaminsonleadlab@emsl.com](mailto:cinnaminsonleadlab@emsl.com)

EMSL Order:	201603665
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**  
**Whitman Companies, Inc.**  
**7 Pleasant Hill Rd**  
**Cranbury, NJ 08512**

Phone: (732) 390-5858  
 Fax: (732) 390-9496  
 Received: 04/06/16 9:00 AM  
 Collected: 4/5/2016

Project: **Parsippany BOE #0710247 / Lake Parsippany Elementary School 225 Kingston Road Parsippany, NJ**

## Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
1	201603665-0001	4/5/2016	4/26/2016	8.72 ppb
Site: LPES / Custodian Office By Boiler Room / UF / 1				
2	201603665-0002	4/5/2016	4/26/2016	<3.00 ppb
Site: LPES / Hall by Girl's Room & Boiler Room / WC / 1				
3	201603665-0003	4/5/2016	4/26/2016	<3.00 ppb
Site: LPES / Old Wing / Hall 1 By Classroom #5 / WC / 1				
4	201603665-0004	4/5/2016	4/26/2016	3.66 ppb
Site: LPES / Old Wing / Hall 2 By Classroom #1 / WC / 1				
5	201603665-0005	4/5/2016	4/26/2016	<3.00 ppb
Site: LPES / Hall 1 By Gym / WC / 1				
6	201603665-0006	4/5/2016	4/26/2016	8.72 ppb
Site: LPES / Hall 2 By Teacher's Rm / WC / 1				
7	201603665-0007	4/5/2016	4/27/2016	6.35 ppb
Site: LPES / Classroom #107 / Preschool / WC / 1				
8	201603665-0008	4/5/2016	4/27/2016	5.66 ppb
Site: LPES / Classroom #110 / Kindergarden / WC / 1				
9	201603665-0009	4/5/2016	4/27/2016	<3.00 ppb
Site: LPES / Media Center By Entrance / WC / 1				
10	201603665-0010	4/5/2016	4/27/2016	3.64 ppb
Site: LPES / Classroom #111 / Kindergarden / WC / 1				
11	201603665-0011	4/5/2016	4/27/2016	3.43 ppb
Site: LPES / Classroom #120 / 1st Grade / WC / 1				
12	201603665-0012	4/5/2016	4/27/2016	<3.00 ppb
Site: LPES / Classroom #115 / Preschool / WC / 1				
13	201603665-0013	4/5/2016	4/27/2016	3.54 ppb
Site: LPES / Classroom #117 / WC / 1				
14	201603665-0014	4/5/2016	4/27/2016	4.99 ppb
Site: LPES / Classroom #201 / 1st Grade / WC / 1				
15	201603665-0015	4/5/2016	4/27/2016	<3.00 ppb
Site: LPES / Classroom #200 / 1st Grade / WC / 1				

Phillip Worby, Lead Laboratory Manager  
 or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 04/28/2016 11:40:07



# EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

[cinnaminsonleadlab@emsl.com](mailto:cinnaminsonleadlab@emsl.com)

EMSL Order:	201603665
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**  
**Whitman Companies, Inc.**  
**7 Pleasant Hill Rd**  
**Cranbury, NJ 08512**

Phone: (732) 390-5858  
 Fax: (732) 390-9496  
 Received: 04/06/16 9:00 AM  
 Collected: 4/5/2016

Project: **Parsippany BOE #0710247 / Lake Parsippany Elementary School 225 Kingston Road Parsippany, NJ**

## Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
16	201603665-0016	4/5/2016	4/27/2016	5.15 ppb
Site: LPES / Classroom #203 / 1st Grade / WC / 1				
17	201603665-0017	4/5/2016	4/27/2016	10.8 ppb
Site: LPES / Classroom #205 / 1st Grade / WC / 1				
18	201603665-0018	4/5/2016	4/27/2016	<3.00 ppb
Site: LPES / Classroom #204 / 2nd Grade / WC / 1				
19	201603665-0019	4/5/2016	4/27/2016	3.67 ppb
Site: LPES / Classroom #207 / 2nd Grade / WC / 1				
20	201603665-0020	4/5/2016	4/27/2016	<3.00 ppb
Site: LPES / Classroom #206 / 2nd Grade / WC / 1				

Phillip Worby, Lead Laboratory Manager  
 or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 04/28/2016 11:40:07