

Parsippany-Troy Hills Board of Education

**Press Release
Office of the Superintendent
May 4, 2016**

Water Testing Northvail and Troy Hills

We notified you earlier that as a result of the issue of lead in the schools drinking water in Newark, New Jersey, the Parsippany-Troy Hills Township School District made the decision to have the water tested in all of our 14 schools. As part of the testing procedures, all drinking fountains, food preparation, and Home Economics classrooms were tested. We told you that as results came in we would notify you and post all results on our district website.

Today we received partial results for Northvail and Troy Hills Elementary Schools. There was an error on the part of the consultant and not all the rooms were tested. The remaining classrooms will be tested. Once the complete results are received we will send them out and post them on the district website as we have done for our other schools.

Northvail Elementary School Partial Results:

Classroom #16 – Special Ed/Basic Skills Reading – 23.4 ppb

Action Plan - As a result, this drinking fountain was turned off today and we will provide bottled water to the staff and students in this classroom.

All other samples in the school were below the threshold.

Troy Hills Elementary School Partial Results:

The Troy Hills Elementary School showed results all below the threshold of 15.0 ppb.

Please understand that the information we have received is preliminary and not the complete report. The steps taken at this point are precautionary. As we receive additional notifications for the remaining schools and complete testing results for all our schools we will post the information on the District website. www.pthsd.k12.nj.us

Below is the link to the updated NJDEP website on lead in drinking water
<http://www.nj.gov/dep/watersupply/dwc-lead.html>

The Township website has the most recent State mandated water quality testing program. This is the link to the most recent water quality testing report.
http://www.parsippany.net/web_content/acrobat/flyers/2012-WaterCCR.pdf

For more information regarding lead in drinking water please visit: <https://www.epa.gov/your-drinking-water/basic-information-about-lead-drinking-water>

If you have questions or concerns, please contact Mr. David Corso, Assistant Superintendent of Schools/Chief Financial Officer at dfcorso@pthsd.net.



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

cinnaminsonleadlab@emsl.com

EMSL Order:	201603868
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 04/13/16 9:00 AM
 Collected: 4/12/2016

Project: **Parsippany BOE / 0710247 / 509 S Beverwyck Rd, Parsippany, NJ Troy Hill Elementary School**

Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
1	201603868-0001	4/12/2016	4/29/2016	<3.00 ppb
Site: THES / Boiler Rm / Main Valve / UF / 1				
2	201603868-0002	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Hall by Audio Rm / WC / 1				
3	201603868-0003	4/12/2016	4/29/2016	3.50 ppb
Site: THES / Nurses Rm / WC / 1				
4	201603868-0004	4/12/2016	4/28/2016	10.0 ppb
Site: THES / Classroom #1 / Kindergarden / WC / 1				
5	201603868-0005	4/12/2016	4/28/2016	3.95 ppb
Site: THES / Classroom #2 / Kindergarden / WC / 1				
6	201603868-0006	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #3 / Kindergarden / WC / 1				
7	201603868-0007	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #4 / Kindergarden / WC / 1				
8	201603868-0008	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #5 / Kindergarden / WC / 1				
9	201603868-0009	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #6 / Kindergarden / WC / 1				
10	201603868-0010	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #7 / Kindergarden / WC / 1				
11	201603868-0011	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #8 / Kindergarden / WC / 1				
12	201603868-0012	4/12/2016	4/28/2016	3.09 ppb
Site: THES / Resource Center / Rm 9 / WC / 1				
13	201603868-0013	4/12/2016	4/28/2016	5.26 ppb
Site: THES / Hall by Storage & Electrical Panel / WC / Left / 1				
14	201603868-0014	4/12/2016	4/28/2016	4.77 ppb
Site: THES / Hall by Storage & Electrical Panel / WC / Right / 1				
15	201603868-0015	4/12/2016	4/28/2016	11.7 ppb
Site: THES / Child Study Team / Rm #10 / WC / 1				

Phillip Worby, Lead Laboratory Manager
 or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 04/29/2016 19:27:24



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

cinnaminsonleadlab@emsl.com

EMSL Order:	201603868
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 04/13/16 9:00 AM
 Collected: 4/12/2016

Project: **Parsippany BOE / 0710247 / 509 S Beverwyck Rd, Parsippany, NJ Troy Hill Elementary School**

Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
16	201603868-0016	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #11 / 1st Grade / WC / 1				
17	201603868-0017	4/12/2016	4/28/2016	<3.00 ppb
Site: THES / Classroom #12 / 1st Grade / WC / 1				
18	201603868-0018	4/12/2016	4/28/2016	4.64 ppb
Site: THES / Hall by Computer Lab / Rm #17 / WC / Left / 1				
19	201603868-0019	4/12/2016	4/28/2016	3.07 ppb
Site: THES / Hall by Computer Lab / Rm #17 / WC / Right / 1				
20	201603868-0020	4/12/2016	4/28/2016	9.81 ppb
Site: THES / Classroom #19 / 3rd Grade / WC / 1				

Phillip Worby, Lead Laboratory Manager
 or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 04/29/2016 19:27:24



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

cinnaminsonleadlab@emsl.com

EMSL Order:	201603931
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 04/14/16 9:00 AM
 Collected: 4/13/2016

Project: **Parsippany BOE #0710247 / Northvail Elementary School 10 Eileen Court Parsippany, NJ**

Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
1	201603931-0001	4/13/2016	5/2/2016	9.38 ppb
Site: NES / Custodian Closet On Back Boiler Rm / Slop Sink / UF / 1				
2	201603931-0002	4/13/2016	5/2/2016	7.51 ppb
Site: NES / Hall by Gym and Multi-Purpose Rm / WC / Left / 1				
3	201603931-0003	4/13/2016	5/2/2016	6.43 ppb
Site: NES / Hall by Gym and Multi-Purpose Rm / WC / Right / 1				
4	201603931-0004	4/13/2016	5/2/2016	6.38 ppb
Site: NES / Nurse's Office / UF / WC / 1				
5	201603931-0005	4/13/2016	5/2/2016	4.63 ppb
Site: NES / Hall Between Boys & Girls Rm / WC / Left / 1				
6	201603931-0006	4/13/2016	5/2/2016	3.09 ppb
Site: NES / Hall Between Boys & Girls Rm / WC / Right / 1				
7	201603931-0007	4/13/2016	5/2/2016	3.50 ppb
Site: NES / Classroom #17 / Kindergarden / WC / 1				
8	201603931-0008	4/13/2016	5/2/2016	6.73 ppb
Site: NES / Classroom #9 / Kindergarden / WC / 1				
9	201603931-0009	4/13/2016	5/2/2016	23.4 ppb
Site: NES / Classroom #16 / Kindergarden / WC / 1				
10	201603931-0010	4/13/2016	5/2/2016	6.47 ppb
Site: NES / Classroom #10 / Kindergarden / WC / 1				
11	201603931-0011	4/13/2016	5/2/2016	12.3 ppb
Site: NES / Classroom #1 / 1st Grade / WC / 1				
12	201603931-0012	4/13/2016	5/2/2016	3.84 ppb
Site: NES / Classroom #2 / 1st Grade / WC / 1				
13	201603931-0013	4/13/2016	5/2/2016	3.12 ppb
Site: NES / Classroom #3 / 1st Grade / WC / 1				
14	201603931-0014	4/13/2016	5/2/2016	4.61 ppb
Site: NES / Classroom #4 / 2nd Grade / WC / 1				
15	201603931-0015	4/13/2016	5/2/2016	4.85 ppb
Site: NES / Classroom #5 / 2nd Grade / WC / 1				

Phillip Worby, Lead Laboratory Manager
or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 05/03/2016 18:15:06



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 786-5974

<http://www.EMSL.com>

cinnaminsonleadlab@emsl.com

EMSL Order:	201603931
CustomerID:	WHIT53
CustomerPO:	
ProjectID:	Parsippany BOE

Attn: **Kevin Lovely**
Whitman Companies, Inc.
7 Pleasant Hill Rd
Cranbury, NJ 08512

Phone: (732) 390-5858
 Fax: (732) 390-9496
 Received: 04/14/16 9:00 AM
 Collected: 4/13/2016

Project: Parsippany BOE #0710247 / Northvail Elementary School 10 Eileen Court Parsippany, NJ

Test Report: Lead in Water by Furnace AAS (EPA 200.9)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Collected</i>	<i>Analyzed</i>	<i>Lead Concentration</i>
16	201603931-0016	4/13/2016	5/2/2016	5.76 ppb
Site: NES / Hall by Rm #12A / WC / Left / 1				
17	201603931-0017	4/13/2016	5/2/2016	3.75 ppb
Site: NES / Hall by Rm #12A / WC / Right / 1				
18	201603931-0018	4/13/2016	5/2/2016	<3.00 ppb
Site: NES / Classroom #14 / 5th Grade / WC / 1				
19	201603931-0019	4/13/2016	5/2/2016	<3.00 ppb
Site: NES / Classroom #22 / 4th Grade / WC / 1				
20	201603931-0020	4/13/2016	5/2/2016	4.06 ppb
Site: NES / Room #23 / ESL / WC / 1				

Phillip Worby, Lead Laboratory Manager
or other approved signatory

The test results contained within this report meet the requirements of NELAC unless otherwise noted. This report relates only to those items tested. Samples received in good condition unless otherwise noted. Quality Control Data associated with this sample set is within acceptable limits, unless otherwise noted. "<" (less than) result signifies that the analyte was not detected at or above the reporting limit. Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NJ-NELAP 03036

Initial report from 05/03/2016 18:15:06